

Appendix H: Inspection Schedule for Rubber Insulating Equipment

NFPA 70E 2018: Table 130.7 (C)(7) – Rubber Insulating Equipment, Maximum Test Intervals

Type of Equipment	When to test
Rubber insulating line hose	Upon indication that insulating value is suspect
Rubber insulating covers	Upon indication that insulating value is suspect
Rubber insulating blankets	Before first issue and every 12 months thereafter*
Rubber insulating gloves	Before first issue and every 6 months thereafter*
Rubber insulating sleeves	Before first issue and every 12 months thereafter*

* New insulating equipment is not permitted to be placed into service unless it has been electrically tested within the previous 12 months. Insulating equipment that has been issued for service and is not new is required to be retested in accordance with the intervals in this table.