

Electrical Safety- Working Space for equipment

Applicable standards:

OSHA 29 CFR 1910.303 (g)

NFPA 70 110.26

600 volts or Less:

- Requires sufficient access and working space around all equipment
- 3ft minimum depth
- 30 inches min. or width of equipment which ever is greater
- Working space shall permit at least a 90 degree opening of equipment doors or hinged panels
- Working space required by these standards may not be used for storage

Minimum Access Clearance Around a Service Panel

